

## Guardian Free-Standing Drench Shower & Eye Wash



PLS1618 Pedestal Mount; Plumbed, Flow Rate  
Eyewash – 1.6 gal./Minute, Shower - 20 gal./Minute

Two-in-one decontamination station provides easy access to drench shower and eyewash to minimize injuries from accidental exposure.

- Combination safety shower and eyewash station can be installed in high-risk areas to provide onsite initial treatment
- Chrome-plated brass valves with PTFE seals stay open until manually closed for complete decontamination
- Drench shower features stainless steel actuating arm and pull rod to easily activate water flow during an emergency
- Eye wash bowl with two spray heads delivers a flood of water for rinsing eyes; large push flag is easy to activate, even when vision is compromised
- Spray heads include flip-top dust covers plus internal flow control and filter to remove impurities
- Bright orange color (shower head, bowl and pipe covers) is highly visible so workers can quickly locate decon station
- Assembled, inspected and water-tested before shipment to ensure quality and reliable performance at your facility



### Specifications

<b>Style</b>	Pedestal Mount; Plumbed
<b>Brand</b>	Guardian
<b>Capacity</b>	Unlimited
<b>Dispensing Method</b>	Plumbed
<b>Flow Rate</b>	Eyewash – 1.6 gal./Minute, Shower - 20 gal./Minute
<b>Sold as</b>	1 each
<b>Color</b>	Orange
<b>Weight</b>	41 lbs.
<b># per Pallet</b>	8
<b>Composition</b>	Shower Head, Eyewash Bowl: ABS Plastic

Shower and Eyewash Valves: Chrome Plated Brass  
Actuating Arm, Pull Rod: Stainless Steel  
Pipe and Fittings: Schedule 40 Galvanized Steel  
Pipe Covers: Polyethylene

**UNSPSC**

46181810

**Pigalog® Page Number**

Page 203

**Metric Equivalent**

**Weight**

18.6 kg

**Technical Information**

**Certifications, Approvals and Ratings**

ANSI Z358.1

**Technical Documents**

Compliance Checklist ANSI / ISEA Z358.1-2014

29 CFR 1910.151(c)



**One Pork Avenue • Tipton, PA 16684-0304**

1-855-493-4647 • Fax: 1-800-621-7447 • [newpig.com](http://newpig.com) • [hothogs@newpig.com](mailto:hothogs@newpig.com)